

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 120

Dated: 18.5.2023

It is certified that an inspection team headed by Surender Kumar Sharma Junior Chemist
 (Name of Officers with designation) from P.H.E.D DISTRICT laboratory Jhunjhunu
 (Name of Department/ Office) inspected the Jhunjhunu Academy Jhunjhunu
 (Name & Address of the school) on 17.5.2023 (date of inspection) and found that the
Jhunjhunu Academy Jhunjhunu (Name of school) has safe drinking water
 facilities for the students and members of staff of the institution and is maintaining the hygienic
 sanitation condition in the school building & the campus as per norms prescribed by the Central/
 State/ U.T. Govt.

The above is valid for a period of 1 year

Signature with Seal: (सुरेन्द्र कुमार शर्मा)
कनिष्ठ रसायनज्ञ
 Name : जन स्वा० अभि० विभाग
 Designation : प्रयोगशाला, झुझुनु

Name & Address of the Office / Department :

To

Jhunjhunu Academy
Jhunjhunu
 (Name & Address of the Institution)

Ravi
 PRINCIPAL
 JHUNJHUNU ACADEMY
 CBSE Affi. No. 1730273
 Jhunjhunu (Raj.) 333001

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Dilip Singh
 PRESIDENT

Jhunjhunu Academy Samity
 Jhunjhunu (Rajasthan)



PUBLIC HEALTH ENGINEERING DEPARTMENT
LABORATORY JHUNJHUNU

CHEMICAL EXAMINATION REPORT OF WATER

No. Lab. / Chem. /2023-24/ 130

Date - 18.5.2023

To,
Jhunjhunu Acedamy
Jhunjhunu International Wisdom City
Near Khemi Sati Temple
Jhunjhunu
Ref- Yours letter dated 17-5-20233


Distt:- Jhunjhunu
Tehsil:-Jhunjhunu

Date of Exam -18-05-2023

A	Name & Location of Source			Water Sample Indu Hospital Jhunjhunu
B	Village/ Town			Jhunjhunu
C	Date Of Collection			15-5-2023
D	Lab. Sample No.			C-10
Sr. No	Parameters	Desirable limits	Permissible limits	Analysed Value
1	pH	6.5—8.5	6.5—8.5	7.43
2	Turbidity[NTU]	1	5	Nil
3	Temperature[C]	-----	-----	25
4	Colour[Units]	5 Hazen Unit	15 Hazen Unit	None
5	Odour	Unobjectionable	Unobjectionable	Unobj.
6	Total Alkalinity[asCaCO ₃]	200	600	20
7	Total Hardness[asCaCO ₃]	200	600	16
8	Calcium [asCa]	75	200	4
9	Magnesium [as Mg]	30	100	1.44
10	Chloride[asCl ⁻¹]	250	1000	12
11	Nitrate[as NO ₃ ⁻¹]	45	45	02
12	Fluoride [as F ⁻¹]	1.0	1.5	0.1
13	TDS	500	2000	52

Note: All Results Except pH in mg/L.

Ravi
PRINCIPAL
JHUNJHUNU ACADEMY
CBSE Affi. No. 1730273
Jhunjhunu (Raj.) 333001



S.K. Sharma

PRESIDENT

Jhunjhunu Academy Samity
Jhunjhunu (Rajasthan)